

# Glass and Glazing Federation

Certifies that

*Pentagon International.*

Certificate No: **TC 0347**

8 MIL Clear Safety Film has passed Class 1B2  
Of BS EN 12600 'Glass in Building – Pendulum  
Test – Impact Test Method and Classification  
For Flat Glass' on 4 and 6 mm Float Glass

Tested at Wintech Engineering Ltd, UKAS accredited Test Laboratory, No.2223


Issued: **28 March 2006**

Chief Executive:



N Rees

Director of Glazing:



S H Rice



Glass and Glazing Federation

Glass and Glazing Federation  
44 – 48 Borough High Street  
London  
SE1 1XB  
Tel: 020 7207 5872  
Fax: 020 7357 7458

Test Facility:  
WİNTECH Engineering Ltd  
Halesfield 2  
Telford TF7 4QH  
Tel: 01952 586580  
Fax: 01952 586585